

9/25

ABDUL WAHID & ASSOCIATES
CONSULTING ARCHITECTS, STRUCTURAL ENGINEERS & INTERIOR DESIGNERS
 216, Essel House, Asif Ali Road, New Delhi. 110002
 Phone :- 011-23230765 Mob. :- 9999079216
 E- mail :- A.wahid216@gmail.com

Ref. No. :- AWA/ST/2022/24

Dated :- 02/06/2022

CERTIFICATE OF STRUCTURAL SAFETY

- | | | |
|---|---|---|
| 1. Name of School | : | Fatehpuri Muslim Senior Secondary School |
| 2. Postal Address | : | Masjid Fatehpuri, Chandni Chowk, Delhi-06 |
| 3. No. of Floor | : | First Floor with Mezzanine Floor,
Second Floor With Mezzanine Floor |
| 4. Nature of work carried out in the premises | : | School which includes Class Rooms, Library,
Assembly Hall, Laboratories, Store,
Sports Room & Drawing Room etc. |

Certified that I, Abdul Wahid Structural Engineer, Inspected the School Building at the request of Manager of Managing Committee Fatehpuri, Muslim Sr. Sec. School, Delhi-110006 on 19/05/2022 along with the representative of the School.

The building has been built prior to 1929. Floor wise area of School building is as follows:-

First Floor _____ :- 1122 Sq.mts.


Mezzanine Floor _____ :- 460 Sq.mts.
(Above First Floor)

Second Floor _____ :- 857 Sq.mts.

Mezzanine Floor _____ :- 460 Sq.mts.
(Above second Floor)

In the absence of Structural Drawings, I visually inspected the Building from various positions. The structure of the building is built up of Bricks, lime and surkhi. The Building is capable to withstand the live loads & wind pressure. The building seems to be well maintained. No visible distress was observed, which include any crack more than 0.2 mm width and deflection more than L/350.

From the observations, I am of considered opinion, that the building is structurally safe, sound and stable for the purpose of school


 02.06.2022
ABDUL WAHID
 STRUCTURAL ENGINEER
 L. No :- SE-65
 216, Essel House, Asif Ali Road,
 New Delhi - 110002
Er. ABDUL WAHID
 STRUCTURAL ENGINEER
 (L. No. SE-65)